



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 7302
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

January 11, 2017

NTA INC
DAVID J. BARTS
305 N OAKLAND AVE
PO BOX 490
NAPPANEE IN 46550

ROCHESTER HOMES INCORPORATED
ENGINEERING DEPT
RUSSELL CONLEY
1345 N LUCAS ST
PO BOX 587
ROCHESTER IN 46975

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: ROCHESTER HOMES INCORPORATED
Product Name: (trans id 2799857) TWO STORY
Model Number(s): TWO STORY
Product File No: 20160308

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2022.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be a minimum as required in SPS 382.40 (7) (d).
- The manufacture must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
- All metallic potable water system components shall conform to NSF/ANSI 372.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail